

FORM VI

(Regulation 389)

CERTIFICATE FOR USE OF A BOILER

NO: 70 Dated : 07/09/2017
GSC.NO : IS0020000004910 Dated : 01/09/2017
Reg. No. of Boiler : KTK-4720 Type of Boiler : Water Tube
Boiler Rating : 6798.4 sq_Mts Place and year: Berlin Germany 1970
of manufacture
Maximum Continuous Evaporation : 140.0 TPH
Name of the Owner : M/s Coromandel Sugars Ltd.
Situation of Boiler : Makavalli 571426
Repairs : REPLACED ALL SECONDARY SUPER
REMARKS : HEATER COILS.

Hydraulically Tested on 06/09/2017 to 157.5 Kg/Sq.cm(g)

I hereby certify that the above described boiler is permitted by me/
under the provisions of Section 7/8 of the Indian Boiler Act, (No. V of 1923), to be worked
at a maximum pressure of 105 Kg/Sq.Cm(g) for the period from
06/09/2017 to 05/09/2018.

The loading of the NULL safety valve is not to exceed 105 Kg/Sq. Cm(g).

Fee Rs.28500 (Boiler)+0 (SteamLine) Paid on 25/03/2017 at E PAYMENT

Dated at

This day, 7th day of September ,2017

Assistant Director of Boilers, Mysore Division
ಬಾಷ್ಪರುಗಳ ಸಹಾಯಕ ನಿರ್ದೇಶಕರು
ಮೈಸೂರು ವಿಭಾಗ, ಮೈಸೂರು

Open up for cleaning after every 16 Weeks. See on the reverse for the conditions and keep record.

CONDITIONS
(Reverse of Form VI)

- (1) No structural alteration, addition or renewal shall be made to the boiler otherwise than in accordance with section 12 of the Act.
- (2) Under the provisions of Section 8 of the Act this certificate shall cease to be in force:
- (a) on the expiry of the period for which it was granted; or
 - (b) when any accident occurs to the boiler; or
 - (c) when the boiler is moved the boiler not being vertical boiler the heating surface of which is less than eighteen point fifty eight square meters (18.58 Sq. Mts) , or a portable or vehicular boiler; or
 - (d) when any structural alteration, addition or renewal is made in or to the boiler; or
 - (e) if the Chief Inspector in any particular case so directs when any structural alteration, addition or renewal is made in or to any steam-pipe attached to the boiler; or
 - (f) on the communication to the owner of the boiler of an order of the Chief Inspector or Inspector prohibiting its use on the ground that it or any steam-pipe attached thereto is in a dangerous condition.

Under Section 10 of the Act, when the period of a certificate relating to a boiler has expired, the owner shall, provided that he has applied before the expiry of that period for a renewal of the Certificate, be entitled to use the boiler at the maximum pressure entered in the former certificate, pending the issue of orders on the application but this shall not be deemed to authorise the use of a boiler in any of the cases referred to in clause (b), (c), (d), (e) and (f) of sub-section (1) of section 8 occurring after the expiry of the period of the certificate.

- (3) The boiler shall not be used at a pressure greater than the pressure entered in the certificate as the maximum pressure nor with the safety valve set to a pressure exceeding such maximum pressure.
- (4) The boiler shall not be used otherwise than in a condition which the owner reasonably believes to be compatible with safe working.

NOTE.- The particulars and dimensions regarding this boiler may be obtained by the owner on payment in the prescribed manner on application to the Chief Inspector.